




STERG

SOLAR THERMAL ENERGY
RESEARCH GROUP



Integration of solar process heat at a South African microbrewery: a feasibility study

Pieter De Wet Taljaard ^a, Thomas Harms ^a,
and Ben Sebitosi ^b

^a Solar Thermal Energy Research Group (STERG),
Stellenbosch University

^b Department of mechanical and mechatronic engineering,
Stellenbosch University

Background



SA Solar Resource in Industrial Areas

Gauteng



- 2000 kWh/m²

Greater Cape Town

- 1800 kWh/m²

Greater Durban



- 1600 kWh/m²



Background


Industrial Heat demand

Industrial Energy Usage



Sectoral Energy Demand

Fuel Source




Hess 2015, (Adapted from SATIM 2014)

Background

Technology

Temperature
Supplied

Stationary vs
Tracking



Background



Target industries

- Low temperature heat requirement
- Constant heat demand
- High cost fuel source
- Food and beverage, Textile and agri-processing

Background

Berg River Brewery

- Microbrewery in Paarl, WC
- Established in 2016
- Food and Beverage Industry
- Low to medium Temperature requirement



Motivation



SPH at BRB

- Unbiased assessment of SPH
- SPH for small industrial applications

Thermal Demand



Per Brew

Process	Start Temp. [°C]	End Temp. [°C]	Medium	Specific heat [kWh/m ³ K]	Volume [L]	Heat Requirement [kWhth]	Percentage of Heat Requirement
Mashing	18	75	water	1.16	300	19.8	23%
Wort filter	18	75	water	1.16	350	23.1	26%
Boiler/Kettle	75	100	sweet wort	1	600	15.0	17%
Boiling/Hot hold	100	100	wort & hops	1.25	600	30.0	34%

Thermal Demand






Load Profile

3 Brews per day

3 Brewing days per
Brewing week

Seasonal production
variation

Summer vs Winter



System Design




Concept

External heat exchangers

Heat recovery

Preheating strategy

Backup System



System Design



Collector location

North: 180 m² - 23°

South: 250 m² - 21°



System Design



Collector location

North: 180 m² - 23°

South: 250 m² - 21°

Asbestos Roof!!!




System Design



Specifics

- Collector Aperture Area: 18.42 m²
- Storage Volume: 1500 L
- VSD drives on Solar and tank loops
- Stainless steel food grade components



System Performance Modelling




Input

Solar resource

Process characteristics

Heat demand type

SolGain demand profile



System Performance Modelling



Results

Annual Thermal Demand

- 27 170 kWh_{th}


Supplied by SPH

- 19 020 kWh_{th}

Solar Fraction - 70%

System Efficiency - 27%

System Production



Business Case – To Buy or not to Buy



Capex

System Cost

- R 20 800/m²


Minimum

- R 16 000/m²

Maximum

- R31 600/m²

SPH System Component Specific Cost



Business Case – To Buy or not to Buy



LCOH

Period	LCOH - R/kWh _{th}
10 years	R 3.43
20 Years	R 2.62

Discount Rate: 4.8%

Degradation: 0.5%

O&M Cost: R 15 000/annum

Business Case – To Buy or not to Buy



LCOH

Period	LCOH - R/kWh _{th}
10 years	R 3.43
20 Years	R 2.62

Electricity Cost : R1.775 R/kWh

Discount Rate: 4.8%

Degradation: 0.5%

O&M Cost: R 15 000/annum

Business Case – To Buy or not to Buy

Payback Period

- Berg River Brewery – 12.4 Years
- CBC system – 9.3 Years

Business Case – To Buy or not to Buy

Conclusion

- Low system utilisation
- Low Electricity cost
- High system cost

Business Case – To Buy or not to Buy

Conclusion

- Low system utilisation
 - Low Electricity cost
 - High system cost
 - Investigate suitability of alternative technologies
- Not Economically Feasible**

Thank You

ACKNOWLEDGEMENTS:

Berg River Brewery
NRF
STERG

CONTACT DETAILS:

Solar Thermal Energy Research
Group (STERG)
Stellenbosch University
South Africa

STERG@sun.ac.za
+27 (0)21 808 4016

visit us: concentrating.sun.ac.za